

**Fiterman Hall - ACM Microvacuum Samples
ASTM 5755**

Sample Location	Sample ID	Area Sampled	Asbestos Type	Asbestos Structures	Sensitivity	Concentration	Comment
15 - E. Flr. Center	M-01	100 sq. cm.	None Detected	<3	991	<2970	
14 - N. Flr. Center. Rad. Top	M-02	100 sq. cm.	None Detected	<3	991	<2970	
13 - W. Flr. Center	M-03	100 sq. cm.	Amosite Chrysotile	17	2580	43900	
12 - S.E. Cor. Above Ceiling	M-04	100 sq. cm.	Chrysotile	17	1290	21900	
11 - Flr. Staircase B Landing	M-05	100 sq. cm.	None Detected	<3	991	<2970	
10 - E. Cor. Flr.	M-06	100 sq. cm.	Chrysotile	<3	859	<2580	
9 - N. W. Flr.	M-07	100 sq. cm.	None Detected	<3	859	<2580	
8 - W. Flr. Desk Top	M-08	100 sq. cm.	Chrysotile	<3	859	<2580	
7 - S. Flr. Center	M-09	100 sq. cm.	Chrysotile	10	2580	25800	
6 - E. Flr.	M-10	100 sq. cm.	Chrysotile	117	859	101000	
5 - N. Flr. File Cabinet	M-11	100 sq. cm.	Amosite Chrysotile	20	1290	25800	
4 - W Cor. Flr.	M-12	100 sq. cm.	None Detected	<3	515	<1550	
3 - S.W. Flr. Above Ceiling	M-13	100 sq. cm.	Chrysotile	109	1290	141000	
2 - N. Flr. Table Top	M-14	100 sq. cm.	None Detected	<3	859	<2580	
1 - Loading Dock Flr.	M-15	100 sq. cm.	Chrysotile	22	1290	28400	
Basement N. Ctr. Office Above Duct Work	M-16	100 sq. cm.	Tremolite	<3	859	<2580	
Field Blank	M-17	0 sq. cm.	Chrysotile	4			Blank
Field Blank	M-18	0 sq. cm.	None Detected	<3			Blank